

# IEC 61850 Certificate - IEC 61850 Certificate #2589

## TBRT750D-M Transformer Differential Prot [SIFANG TBEA Intelligent Electric Co., Ltd.]

07/08/2021 04:46 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	016PUCA0039
<b>61850 Edition:</b>	Edition 1	<b>Certificate Hash:</b>	89EDD1BE09432E22047060CABA3336 6BF91801501807B6B0253DD3ACA4DB 7096
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	SIFANG TBEA Intelligent Electric Co., Ltd.	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	No 32. Kaifa Blvd, ETDZ, Shenyang City, Liaoning Province, China	<b>Umbrella Organization:</b>	
<b>Product:</b>	TBRT750D-M Transformer Differential Prot	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>		<b>Serial Number:</b>	
<b>SW Version:</b>	V2.0.8598	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>	Differential, Protection, Relay	<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	3.03	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), Setting Group (B4), Setting Group Definition (B4+), Time Synchronization (B13)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	bruce.muschlitz	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	01/19/2017	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	Xuchang KETOP Testing Research Institute Co.(A)		

### Description

This certificate and its information was migrated from a previous database

### History

#1 - 07/08/2021 04:46 PM - Herbert Falk

- File SIFANG TBEA Intelligent Electric Co., Ltd.\_V2.0.8598\_TBRT750D-M Transformer Diff\_2016PUCA0039\_KETOP.pdf added

### Files

SIFANG TBEA Intelligent Electric Co., Ltd.\_V2.0.8598\_TBRT750D-M Transformer Diff\_2016PUCA0039\_KETOP.pdf

Herbert Falk