

IEC 61850 Certificate - IEC 61850 Certificate #2592

SICAM SCC Human Machine Interface [Siemens AG]

07/08/2021 04:46 PM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 2	Test Document:
61850 Tested Aspects:	Client	Certificate Name: 10031229-OPE/INC 17-1762
Company:	Siemens AG	Certificate Hash: AC14881955DD608EC05E5BBDF44FB A78192EF6A0ED649CB078608A03637 30DE7
Address:	IC SG EA PRO Humboldstr. 59 90459 Nuremberg, Germany	Vendor Artifact File Name:
Product:	SICAM SCC Human Machine Interface	Vendor Artifact Hash:
HW Version:	FUJITSU CELSIUS H730 Win7-Enterp	Umbrella Organization:
SW Version:	9.00.00	Optional Reservation Test: No
Key Words:	Comm	Serial Number:
Test Procedure Version:	1.0	Publisher Legacy Variants:
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), Service Tracking (B15), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Publisher Preferred Rates:
Certificate/Result Reviewer:	bruce.muschlitz	Publisher Preferred Variants:
Approval Date:	01/25/2017	Subscriber Legacy Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Variants:
Current Test Lab Name:	DNV Netherlands (A)	Subscriber Preferred Rates:
Description		
This certificate and its information was migrated from a previous database		

History

#1 - 07/08/2021 04:46 PM - Herbert Falk

- File 17-1762_DNVGL_Siemens_SICAM_SCC_ClientEd2_Certificate.pdf added

Files

17-1762_DNVGL_Siemens_SICAM_SCC_ClientEd2_Certificate.pdf	91.4 KB	07/08/2021	Herbert Falk
---	---------	------------	--------------