

IEC 61850 Certificate - IEC 61850 Certificate #2593

PA620-L4 Line Current Differential Relay [Nanjing Intelligent Apparatus Co., Ltd.]

07/08/2021 04:46 PM - Herbert Falk

Status:	Approved	Certificate Name:	10032567-OPE/INC 17-1727
Priority:	Normal	Certificate Hash:	813C8F3E0F4973D15C655A5E707257 D1738C1480008E8FADB72589760EFC 03B9
61850 Edition:	Edition 1	Vendor Artifact File Name:	
61850 Tested Aspects:	Server	Vendor Artifact Hash:	
Company:	Nanjing Intelligent Apparatus Co., Ltd.	Umbrella Organization:	
Address:	52#, East Tianyuan Road, Jiangning Science Park, Nanjing, Jiangsu Province, P.R. China	Optional Reservation Test:	No
Product:	PA620-L4 Line Current Differential Relay	Serial Number:	
HW Version:		Publisher Legacy Variants:	
SW Version:	V3.0	Publisher Preferred Rates:	
Key Words:	Differential, Protection, Relay	Publisher Preferred Variants:	
Test Procedure Version:	3.03	Subscriber Legacy Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Preferred Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Rates:	
Approval Date:	02/18/2017	Product Variants:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Test Document:			
Description This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:46 PM - Herbert Falk

- File 17-1727_DNVGL_Nanjing_INT_PA620-L4_ServerEd1_Certificate.pdf added

Files

17-1727_DNVGL_Nanjing_INT_PA620-L4_ServerEd1_Certificate.pdf 91.2 KB

07/08/2021

Herbert Falk