

# IEC 61850 Certificate - IEC 61850 Certificate #2594

## Easergy MiCOM P139, Feeder Mgmt and BCU [Schneider Electric - Energy Division]

07/08/2021 04:46 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	10030574-OPE/INC 17-1891
<b>61850 Edition:</b>	Edition 2	<b>Certificate Hash:</b>	30457C0A9F57194F509DF8763A58D2F 5832E75804D227059241C2A0ACF2B15 EF
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	Schneider Electric - Energy Division	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	Steinheimer Str. 117 D-63500 Seligenstadt Germany	<b>Umbrella Organization:</b>	Schneider Electric
<b>Product:</b>	Easergy MiCOM P139, Feeder Mgmt and BCU	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>	316	<b>Serial Number:</b>	
<b>SW Version:</b>	P139 -660 -707 -250	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>	Bay Controller, Protection, Relay	<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	1.0	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	bruce.muschlitz	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	02/26/2017	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	DNV Netherlands (A)		

### Description

This certificate and its information was migrated from a previous database

### History

#1 - 07/08/2021 04:46 PM - Herbert Falk

- File 17-1891\_DNVGL\_SchneiderElectric\_P139\_ServerEd2\_Certificate.pdf added

#2 - 07/09/2021 09:31 AM - Herbert Falk

- Umbrella Organization set to Schneider Electric

### Files

17-1891\_DNVGL\_SchneiderElectric\_P139\_ServerEd2\_Certificate.pdf 99.5 KB

07/08/2021

Herbert Falk