

IEC 61850 Certificate - IEC 61850 Certificate #2595

Nexus 1500+ Power Quality Revenue Meter [Electro Industries/GaugeTech]

07/08/2021 04:46 PM - Herbert Falk

Status:	Approved	Certificate Name:	10034644-OPE/INC 17-2007
Priority:	Normal	Certificate Hash:	A4F9FA02E12F859CF138CD2D6AC222 AA160F4BEF2EA13C8EDF59E55E22F5 1169
61850 Edition:	Edition 2	Vendor Artifact File Name:	
61850 Tested Aspects:	Server	Vendor Artifact Hash:	
Company:	Electro Industries/GaugeTech	Umbrella Organization:	
Address:	1800 Shames Drive Westbury, NY 11590-1730 USA	Optional Reservation Test:	No
Product:	Nexus 1500+ Power Quality Revenue Meter	Serial Number:	
HW Version:		Publisher Legacy Variants:	
SW Version:	15.6002	Publisher Preferred Rates:	
Key Words:	Measurement	Publisher Preferred Variants:	
Test Procedure Version:	1.0	Subscriber Legacy Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Preferred Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Product Variants:	
Approval Date:	03/29/2017		
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Test Document:			

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:46 PM - Herbert Falk

- File 17-2007_DNVGL_ElectroIndustries-NEXUS 1500_plus_ServerEd2_Certificate.pdf added

Files

17-2007_DNVGL_ElectroIndustries-NEXUS 1500_plus_ServerEd2_Certificate.pdf 07/08/2021

Herbert Falk