

IEC 61850 Certificate - IEC 61850 Certificate #2601

FOCS-LTB420 Fiber optic current sensor [ABB Schweiz AG]

07/08/2021 04:46 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	1KHL050112
61850 Edition:	Edition 1	Certificate Hash:	161BFBC9EEC736A7C07728B2BECF3 03DC3FDED00BEC9FC7BDB9A55D4E 959030B
61850 Tested Aspects:	Merging Unit	Vendor Artifact File Name:	
Company:	ABB Schweiz AG	Vendor Artifact Hash:	
Address:	Jurastrasse 45 5430 Wettingen Switzerland	Umbrella Organization:	
Product:	FOCS-LTB420 Fiber optic current sensor	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	1.0.0.4	Publisher Legacy Variants:	F12800S8I14U4, F15360S8I4U4, F4000S114U4, F4800S114U4
Key Words:	Measurement, Merging Unit	Publisher Preferred Rates:	
Test Procedure Version:	1.1	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Sampled Value Publish (11a)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	04/18/2017	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-2, 61850-9-2, UCAlug 9-2LE		
Current Test Lab Name:	ABB Switzerland Ltd. (B)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:47 PM - Herbert Falk

- File 1KHL050112_IEC61850_9_2_LE_ConformanceCertificate_FOCS_LTB420_v1004.pdf added

#2 - 06/13/2022 03:10 PM - Bruce Muschlitz

- Address updated

- Publisher Legacy Variants F12800S8I14U4, F15360S8I4U4, F4000S114U4, F4800S114U4 added

Files

1KHL050112_IEC61850_9_2_LE_ConformanceCertificate_FOCS_LTB420_v1004.pdf 07/08/2021

Herbert Falk