

IEC 61850 Certificate - IEC 61850 Certificate #2603

USP-100M Bushing & Tap Changer Monitorin [Hanbit EDS Co., Ltd.]

07/08/2021 04:47 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	2017TS01166
61850 Edition:	Edition 1	Certificate Hash:	F700BD53C59C53FAD815B9DA0EFD5 CD6D9FD186D0370B1AFE605BE34B9 00D70D
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Hanbit EDS Co., Ltd.	Vendor Artifact Hash:	
Address:	44-10 Techno 10-ro, Yuseong-gu, Daejeon 305510 Republic of Korea	Umbrella Organization:	
Product:	USP-100M Bushing & Tap Changer Monitorin	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	1.0	Publisher Legacy Variants:	
Key Words:	Measurement	Publisher Preferred Rates:	
Test Procedure Version:	3.03	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Enhanced SBO Control (12d), Time Synchronization (B13)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	05/08/2017	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Korea Electrotechnology Research Institute (A)		

Description
This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:47 PM - Herbert Falk

- File 2017TS01166_HanbitEDS_USP-100M_Server1.0_KERI.pdf added

Files

2017TS01166_HanbitEDS_USP-100M_Server1.0_KERI.pdf	2.14 MB	07/08/2021	Herbert Falk
---	---------	------------	--------------