

IEC 61850 Certificate - IEC 61850 Certificate #2604

HBCIDAS Circuit Breaker Monitoring Devic [Hanbit EDS Co., Ltd.]

07/08/2021 04:47 PM - Herbert Falk

Status:	Approved	Certificate Name:	2017TS01168
Priority:	Normal	Certificate Hash:	56E616F995EAFCA7E7D584772109EE 3D8F397CDB2CEEEE79C296A4A5EFA 82FD9
61850 Edition:	Edition 1	Vendor Artifact File Name:	
61850 Tested Aspects:	Server	Vendor Artifact Hash:	
Company:	Hanbit EDS Co., Ltd.	Umbrella Organization:	
Address:	44-10 Techno 10-ro, Yuseong-gu, Daejeon 305510 Republic of Korea	Optional Reservation Test:	No
Product:	HBCIDAS Circuit Breaker Monitoring Devic	Serial Number:	
HW Version:		Publisher Legacy Variants:	
SW Version:	1.0	Publisher Preferred Rates:	
Key Words:	Comm, Measurement	Publisher Preferred Variants:	
Test Procedure Version:	3.03	Subscriber Legacy Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Enhanced SBO Control (12d), Time Synchronization (B13)	Subscriber Preferred Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Rates:	
Approval Date:	05/08/2017	Product Variants:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Korea Electrotechnology Research Institute (A)		
Test Document:			

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:47 PM - Herbert Falk

- File 2017TS01168_HanbitEDS_HBCIDAS_Server1.0_KERI.pdf added

Files

2017TS01168_HanbitEDS_HBCIDAS_Server1.0_KERI.pdf	2.1 MB	07/08/2021	Herbert Falk
--	--------	------------	--------------