

IEC 61850 Certificate - IEC 61850 Certificate #2605

MFP-H2SB Overcurrent protection relay [Mitsubishi Electric Corporation]

07/08/2021 04:47 PM - Herbert Falk

Status:	Approved	Certificate Name:	10035067-INC 17-2112
Priority:	Normal	Certificate Hash:	BCCD6D95AC1D5311322AA24774A1C BDD59902BBA2F37116115E3D4CF1F4 87E57
61850 Edition:	Edition 1	Vendor Artifact File Name:	
61850 Tested Aspects:	Server	Vendor Artifact Hash:	
Company:	Mitsubishi Electric Corporation	Umbrella Organization:	
Address:	1-1-2 Wadasaki-Cho, Hyogo-ku 652-8555 Kobe Japan	Optional Reservation Test:	No
Product:	MFP-H2SB Overcurrent protection relay	Serial Number:	
HW Version:	652PSA	Publisher Legacy Variants:	
SW Version:	PGKK0308	Publisher Preferred Rates:	
Key Words:	IOC, Protection, Relay, TOC	Publisher Preferred Variants:	
Test Procedure Version:	3.03	Subscriber Legacy Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Preferred Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Product Variants:	
Approval Date:	05/09/2017		
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Test Document:			
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:47 PM - Herbert Falk

- File 17-2112_DNVGL_Mitsubishi_MFP-H2SB_ServerEd1_Certificate.pdf added

Files

17-2112_DNVGL_Mitsubishi_MFP-H2SB_ServerEd1_Certificate.pdf	91 KB	07/08/2021	Herbert Falk
---	-------	------------	--------------