

IEC 61850 Certificate - IEC 61850 Certificate #2606

INGEPAC EF-MD3 Multifunctional P&C Relay [Ingeteam Power Technology, S.A.]

07/08/2021 04:47 PM - Herbert Falk

Status:	Approved	Certificate Name:	10034644-OPE/INC 17-2007
Priority:	Normal	Certificate Hash:	50981114005C57C996B03D3F11BEC4 92AA5D12887DF7D9E59928AB5CB5B2 5DC9
61850 Edition:	Edition 2	Vendor Artifact File Name:	
61850 Tested Aspects:	Server	Vendor Artifact Hash:	
Company:	Ingeteam Power Technology, S.A.	Umbrella Organization:	
Address:	Power Grid Automation - PGA Parque Tecnologico de Bizkaia, Edificio 110 48170 Zamudio, Bizkaia Spain	Optional Reservation Test:	No
Product:	INGEPAC EF-MD3 Multifunctional P&C Relay	Serial Number:	
HW Version:	BCAAABCCDFEA-T-T-L-L-H-D-A---	Publisher Legacy Variants:	
SW Version:	6.0.17.0	Publisher Preferred Rates:	
Key Words:	Protection, Relay	Publisher Preferred Variants:	
Test Procedure Version:	1.0	Subscriber Legacy Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Service Tracking (B15), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Preferred Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Rates:	
Approval Date:	05/09/2017	Product Variants:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Test Document:			

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:47 PM - Herbert Falk

- File 17-2141_DNVGL_Ingeteam_INGEPAC_EF_ServerEd2_Certificate.pdf added

Files

17-2141_DNVGL_Ingeteam_INGEPAC_EF_ServerEd2_Certificate.pdf 93.6 KB

07/08/2021

Herbert Falk