IEC 61850 Certificate - IEC 61850 Certificate #2607

Accura2700M Motor Management System [Rootech, Inc.]

07/08/2021 04:47 PM - Herbert Falk

Status: Approved

Priority: Normal

61850 Edition: Edition 2

61850 Tested Aspects:

Server

Company: Rootech, Inc. **Test Document:**

Certificate Name: 2017TS01167

Certificate Hash: 4C55C05AA33155BD0CE3B9C7B6C0C

3C2D8AC15D17DC7D6111F2DA70364

84F846

Address: 88, Sin won-ro, Yeongtong-gu, Suwon,

> Gyeonggi-do, 16681 Republic of Korea

Accura2700M Motor Management Product:

System

Vendor Artifact Hash:

Vendor Artifact File

Umbrella

Organization:

SW Version: F1.0.0 Optional Reservation No

Test:

Name:

Serial Number: Key Words: Protection, Relay

Test Procedure

Version:

HW Version:

1.0

Publisher Legacy

Variants:

IEC 61850 Blocks Basic Exchange (B1), Buffered

Certified:

Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), SBO Control (12b), Unbuffered Reporting (B5) **Publisher Preferred**

Rates:

Certificate/Result

Approval Date:

Current Test Lab

Reviewer:

bruce.muschlitz

05/11/2017

Publisher Preferred

Variants:

Subscriber Legacy

Variants:

Standards Tested: 61850-6, 61850-7-1, 61850-7-2,

61850-7-3, 61850-7-4, 61850-8-1 Korea Electrotechnology Research

Name: Institute (A) **Subscriber Preferred**

Variants:

Subscriber Preferred

Rates:

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:47 PM - Herbert Falk

- File 2017TS01167_Rootech_Accura2700M_Server2.0_KERI.pdf added

Files

2017TS01167_Rootech_Accura2700M_Server2.0_KERI.pdf 2.75 MB 07/08/2021 Herbert Falk

04/16/2024 1/1