

# IEC 61850 Certificate - IEC 61850 Certificate #2608

## MiCOM P633 Transformer Differential Prot [Schneider Electric Industries SAS ]

07/08/2021 04:47 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Certificate Name:</b>	VAL_MiCOM_P633_660-250_Ed2
<b>Priority:</b>	Normal	<b>Certificate Hash:</b>	E7470306255749151CE65AAC6E32E8 FCD207EC671FC5EE8C84DBFF64370 00612
<b>61850 Edition:</b>	Edition 2	<b>Vendor Artifact File Name:</b>	
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact Hash:</b>	
<b>Company:</b>	Schneider Electric Industries SAS	<b>Umbrella Organization:</b>	Schneider Electric
<b>Address:</b>	35 rue Joseph Monier 92500 Rueil-Malmaison, France	<b>Optional Reservation Test:</b>	No
<b>Product:</b>	MiCOM P633 Transformer Differential Prot	<b>Serial Number:</b>	
<b>HW Version:</b>		<b>Publisher Legacy Variants:</b>	
<b>SW Version:</b>		<b>Publisher Preferred Rates:</b>	
<b>Key Words:</b>	Differential, Protection, Relay	<b>Publisher Preferred Variants:</b>	
<b>Test Procedure Version:</b>	1.0	<b>Subscriber Legacy Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Preferred Variants:</b>	
<b>Certificate/Result Reviewer:</b>	bruce.muschlitz	<b>Subscriber Preferred Rates:</b>	
<b>Approval Date:</b>	05/16/2017	<b>Product Variants:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	Schneider-Electric China (B)		
<b>Test Document:</b>			
<b>Description</b>			
This certificate and its information was migrated from a previous database			

### History

#1 - 07/08/2021 04:47 PM - Herbert Falk

- File SchneiderElectric\_VAL\_MiCOM\_P633-660-250\_ServerEd2\_Certificate.pdf added

#2 - 07/09/2021 09:31 AM - Herbert Falk

- Umbrella Organization set to Schneider Electric

### Files

SchneiderElectric\_VAL\_MiCOM\_P633-660-250\_ServerEd2\_Certificate.pdf 207 KB

07/08/2021

Herbert Falk