

IEC 61850 Certificate - IEC 61850 Certificate #2609

MiCOM P632 Transformer Differential Prot [Schneider Electric Industries SAS]

07/08/2021 04:47 PM - Herbert Falk

Status:	Approved	Certificate Name:	VAL_MiCOM_P632_660-250_Ed2
Priority:	Normal	Certificate Hash:	E26B46CA677C58861590F40101711C0 254BBF7A02DEECB409408515C5855A 1CB
61850 Edition:	Edition 2	Vendor Artifact File Name:	
61850 Tested Aspects:	Server	Vendor Artifact Hash:	
Company:	Schneider Electric Industries SAS	Umbrella Organization:	Schneider Electric
Address:	35 rue Joseph Monier 92500 Rueil-Malmaison, France	Optional Reservation Test:	No
Product:	MiCOM P632 Transformer Differential Prot	Serial Number:	
HW Version:		Publisher Legacy Variants:	
SW Version:		Publisher Preferred Rates:	
Key Words:	Differential, Protection, Relay	Publisher Preferred Variants:	
Test Procedure Version:	1.0	Subscriber Legacy Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Preferred Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Rates:	
Approval Date:	05/16/2017	Product Variants:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Time Activated Control:	
Current Test Lab Name:	Schneider-Electric China (B)		
Test Document:			
Description This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:47 PM - Herbert Falk

- File SchneiderElectric_VAL_MiCOM_P632-660-250_ServerEd2_Certificate.pdf added

#2 - 07/09/2021 09:31 AM - Herbert Falk

- Umbrella Organization set to Schneider Electric

Files

SchneiderElectric_VAL_MiCOM_P632-660-250_ServerEd2_Certificate.pdf 204 KB

07/08/2021

Herbert Falk