

IEC 61850 Certificate - IEC 61850 Certificate #2610

MiCOM P631 Transformer Differential Prot [Schneider Electric Industries SAS]

07/08/2021 04:47 PM - Herbert Falk

Status:	Approved	Certificate Name:	VAL_MiCOM_P631_660-250_Ed2
Priority:	Normal	Certificate Hash:	D16B5CC55003DF3DDD0B1951F36FD 44D5496548DE64026E94707567EC196 556B
61850 Edition:	Edition 2	Vendor Artifact File Name:	
61850 Tested Aspects:	Server	Vendor Artifact Hash:	
Company:	Schneider Electric Industries SAS	Umbrella Organization:	Schneider Electric
Address:	35 rue Joseph Monier 92500 Rueil-Malmaison, France	Optional Reservation Test:	No
Product:	MiCOM P631 Transformer Differential Prot	Serial Number:	
HW Version:		Publisher Legacy Variants:	
SW Version:		Publisher Preferred Rates:	
Key Words:	Differential, Protection, Relay	Publisher Preferred Variants:	
Test Procedure Version:	1.0	Subscriber Legacy Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Preferred Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Rates:	
Approval Date:	05/16/2017	Product Variants:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Schneider-Electric China (B)		
Test Document:			

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:47 PM - Herbert Falk

- File SchneiderElectric_VAL_MiCOM_P631-660-250_ServerEd2_Certificate.pdf added

#2 - 07/09/2021 09:31 AM - Herbert Falk

- Umbrella Organization set to Schneider Electric

Files

SchneiderElectric_VAL_MiCOM_P631-660-250_ServerEd2_Certificate.pdf 228 KB

07/08/2021

Herbert Falk