

IEC 61850 Certificate - IEC 61850 Certificate #2611

MiCOM P439 Distance Protection and Contr [Schneider Electric Industries SAS]

07/08/2021 04:47 PM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 2	Certificate Name: MiCOM_P439_660-250_Ed2
61850 Tested Aspects:	Server	Certificate Hash: 6EBF4A4DFC895A969D9886197AF56782814C37714A94E4DAAA41A409503D1447
Company:	Schneider Electric Industries SAS	Vendor Artifact File Name:
Address:	35 rue Joseph Monier 92500 Rueil-Malmaison, France	Vendor Artifact Hash:
Product:	MiCOM P439 Distance Protection and Contr	Umbrella Organization: Schneider Electric
HW Version:		Optional Reservation Test: No
SW Version:		Serial Number:
Key Words:	Distance, Protection, Relay	Publisher Legacy Variants:
Test Procedure Version:	1.0	Publisher Preferred Rates:
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Time Synchronization (B13), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Legacy Variants:
Approval Date:	05/16/2017	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates:
Current Test Lab Name:	Schneider-Electric China (B)	Product Variants:
Test Document:		Time Activated Control:
Description This certificate and its information was migrated from a previous database		

History

#1 - 07/08/2021 04:47 PM - Herbert Falk

- File SchneiderElectric_VAL_MiCOM_P439-660-250_ServerEd2_Certificate.pdf added

#2 - 07/09/2021 09:31 AM - Herbert Falk

- Umbrella Organization set to Schneider Electric

Files

SchneiderElectric_VAL_MiCOM_P439-660-250_ServerEd2_Certificate2021	228 KB	07/08/2021	Herbert Falk
--	--------	------------	--------------