

IEC 61850 Certificate - IEC 61850 Certificate #2614

MiCOM P132 Feeder Management and Bay Con [Schneider Electric Industries SAS]

07/08/2021 04:47 PM - Herbert Falk

Status:	Approved	Certificate Name:	VAL_MiCOM_P132_660-250_Ed2
Priority:	Normal	Certificate Hash:	093507E3DC4E656D8E08D41C9E2981 9E2D010D77BD00DC04AEA228FD0FE DC5AD
61850 Edition:	Edition 2	Vendor Artifact File Name:	
61850 Tested Aspects:	Server	Vendor Artifact Hash:	
Company:	Schneider Electric Industries SAS	Umbrella Organization:	Schneider Electric
Address:	35 rue Joseph Monier 92500 Rueil-Malmaison, France	Optional Reservation Test:	No
Product:	MiCOM P132 Feeder Management and Bay Con	Serial Number:	
HW Version:		Publisher Legacy Variants:	
SW Version:		Publisher Preferred Rates:	
Key Words:	Protection, Relay	Publisher Preferred Variants:	
Test Procedure Version:	1.0	Subscriber Legacy Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Preferred Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Rates:	
Approval Date:	05/16/2017	Product Variants:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Schneider-Electric China (B)		
Test Document:			

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:47 PM - Herbert Falk

- File SchneiderElectric_VAL_MiCOM_P132-660-250_ServerEd2_Certificate.pdf added

#2 - 07/09/2021 09:31 AM - Herbert Falk

- Umbrella Organization set to Schneider Electric

Files

SchneiderElectric_VAL_MiCOM_P132-660-250_ServerEd2_Certificate.pdf 224 KB

07/08/2021

Herbert Falk