

IEC 61850 Certificate - IEC 61850 Certificate #2616

MiCOM P532 Line-Diff and Bay Control Uni [Schneider Electric Industries SAS]

07/08/2021 04:47 PM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 2	Certificate Name: 0 17 04 89191 014
61850 Tested Aspects:	Server	Certificate Hash: 172E1FCDB1E9E4065A7E62BE347FF2E7565B55222FF6D0C6C5F13A31BC525C07
Company:	Schneider Electric Industries SAS	Vendor Artifact File Name:
Address:	35 rue Joseph Monier 92500 Rueil-Malmaison, France	Vendor Artifact Hash:
Product:	MiCOM P532 Line-Diff and Bay Control Uni	Umbrella Organization: Schneider Electric
HW Version:		Optional Reservation Test: No
SW Version:	660-250	Serial Number:
Key Words:	Bay Controller, Differential, Protection, Relay	Publisher Legacy Variants:
Test Procedure Version:	1.0	Publisher Preferred Rates:
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Time Synchronization (B13), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Legacy Variants:
Approval Date:	05/18/2017	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates:
Current Test Lab Name:	TUV SUD China Ltd (A)	Product Variants:
Test Document:		Time Activated Control:
Description This certificate and its information was migrated from a previous database		

History

- #1 - 07/08/2021 04:47 PM - Herbert Falk
- File 17-D 17 04 89191 014-Schneider Electric_P532_IEC61850Ed2-Server-Certif added
- #2 - 07/09/2021 09:31 AM - Herbert Falk
- Umbrella Organization set to Schneider Electric

Files

17-D 17 04 89191 014-Schneider Electric_P532_IEC61850Ed2-Server-Certif.pdf	07/08/2021	Herbert Falk
--	------------	--------------