

IEC 61850 Certificate - IEC 61850 Certificate #2618

CZAT 7 CPU with PSU, DOU, DIOU, DIU and [ELESTER-PKP Sp. z o.o.]

07/08/2021 04:47 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	10035088-INC 17-2049
61850 Edition:	Edition 1	Certificate Hash:	F93675A3D3D958F0568DD3AFD5A920 4A4DD4F6ECF8AE59BC52A2C9C8349 EA71D
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	ELESTER-PKP Sp. z o.o.	Vendor Artifact Hash:	
Address:	81 Pogonowskiego St. 90-569 Lodz Poland	Umbrella Organization:	
Product:	CZAT 7 CPU with PSU, DOU, DIOU, DIU and	Optional Reservation Test:	No
HW Version:	V1.0 and S/N: 11141011	Serial Number:	
SW Version:	1.0	Publisher Legacy Variants:	
Key Words:	Protection, Relay	Publisher Preferred Rates:	
Test Procedure Version:	3.03	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	05/24/2017	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:47 PM - Herbert Falk

- File 17-2049_DNVGL_ElesterPKP_CZAT7_ServerEd1_Certificate.pdf added

Files

17-2049_DNVGL_ElesterPKP_CZAT7_ServerEd1_Certificate.pdf	90 KB	07/08/2021	Herbert Falk
--	-------	------------	--------------