

**IEC 61850 Certificate - IEC 61850 Certificate #2619**

**PRS-7741 Advanced Monitoring and Control [CYG SUNRI Co., Ltd.]**

07/08/2021 04:47 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Certificate Name:</b>	0 17 05 92391 020
<b>Priority:</b>	Normal	<b>Certificate Hash:</b>	D0C241DC8D36D93C0120FE6A456F33 2623854FC9DBD643D006424EAFFA6A 5BAA
<b>61850 Edition:</b>	Edition 2	<b>Vendor Artifact File Name:</b>	
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact Hash:</b>	
<b>Company:</b>	CYG SUNRI Co., Ltd.	<b>Umbrella Organization:</b>	
<b>Address:</b>	No. 13, Keji North 1st Road, North Area of Hi-Tech Industrial Park, Nanshan District, Shenzhen518057, China	<b>Optional Reservation Test:</b>	No
<b>Product:</b>	PRS-7741 Advanced Monitoring and Control	<b>Serial Number:</b>	
<b>HW Version:</b>		<b>Publisher Legacy Variants:</b>	
<b>SW Version:</b>	1.00	<b>Publisher Preferred Rates:</b>	
<b>Key Words:</b>	Measurement, Protection	<b>Publisher Preferred Variants:</b>	
<b>Test Procedure Version:</b>	1.0	<b>Subscriber Legacy Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Service Tracking (B15), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Preferred Variants:</b>	
<b>Certificate/Result Reviewer:</b>	bruce.muschlitz	<b>Subscriber Preferred Rates:</b>	
<b>Approval Date:</b>	05/24/2017	<b>Product Variants:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	<b>Time Activated Control:</b>	
<b>Current Test Lab Name:</b>	TUV SUD China Ltd (A)		
<b>Test Document:</b>			

**Description**  
This certificate and its information was migrated from a previous database

**History**

#1 - 07/08/2021 04:47 PM - Herbert Falk

- File 17-D 17 05 92391 020-CYG SUNRI\_PRS-7741\_IEC61850Ed2-Server-Certificate.pdf added

**Files**

17-D 17 05 92391 020-CYG SUNRI\_PRS-7741\_IEC61850Ed2-Server-Certificate.pdf 07/08/2021

Herbert Falk