

IEC 61850 Certificate - IEC 61850 Certificate #2622

PRS-778 Transformer Protection Relay [CYG SUNRI Co., Ltd.]

07/08/2021 04:47 PM - Herbert Falk

Status:	Approved	Certificate Name:	D 17 05 92391 023
Priority:	Normal	Certificate Hash:	9CA4A482039648FEFEAAAFDCB1B00 69DBBA3915E0FD7FC92C51AA500767 EFA6D
61850 Edition:	Edition 2	Vendor Artifact File Name:	
61850 Tested Aspects:	Server	Vendor Artifact Hash:	
Company:	CYG SUNRI Co., Ltd.	Umbrella Organization:	
Address:	No. 13, Keji North 1st Road, North Area of Hi-Tech Industrial Park, Nanshan District, Shenzhen518057, China	Optional Reservation Test:	No
Product:	PRS-778 Transformer Protection Relay	Serial Number:	
HW Version:		Publisher Legacy Variants:	
SW Version:	1.00	Publisher Preferred Rates:	
Key Words:	Differential, Protection, Relay	Publisher Preferred Variants:	
Test Procedure Version:	1.0	Subscriber Legacy Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Service Tracking (B15), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Preferred Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Rates:	
Approval Date:	05/24/2017	Product Variants:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Time Activated Control:	
Current Test Lab Name:	TUV SUD China Ltd (A)		
Test Document:			

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:47 PM - Herbert Falk

- File 17-D 17 05 92391 023-CYG SUNRI_PRS-778_IEC61850Ed2-Server-Certificate. added

Files

