

# IEC 61850 Certificate - IEC 61850 Certificate #2623

## PRS-7367 Protection , Automation and Bay [CYG SUNRI Co., Ltd. ]

07/08/2021 04:47 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Certificate Name:</b>	0 17 05 92391 024
<b>Priority:</b>	Normal	<b>Certificate Hash:</b>	A3894366F4C7F5893547A6B590822DC D7964368D9B81AA18C2357F1DDCBC AE72
<b>61850 Edition:</b>	Edition 2	<b>Vendor Artifact File Name:</b>	
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact Hash:</b>	
<b>Company:</b>	CYG SUNRI Co., Ltd.	<b>Umbrella Organization:</b>	
<b>Address:</b>	No. 13, Keji North 1st Road, North Area of Hi-Tech Industrial Park, Nanshan District, Shenzhen518057, China	<b>Optional Reservation Test:</b>	No
<b>Product:</b>	PRS-7367 Protection , Automation and Bay	<b>Serial Number:</b>	
<b>HW Version:</b>		<b>Publisher Legacy Variants:</b>	
<b>SW Version:</b>	1.00	<b>Publisher Preferred Rates:</b>	
<b>Key Words:</b>	Bay Controller, Protection, Relay	<b>Publisher Preferred Variants:</b>	
<b>Test Procedure Version:</b>	1.0	<b>Subscriber Legacy Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Service Tracking (B15), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Preferred Variants:</b>	
<b>Certificate/Result Reviewer:</b>	bruce.muschlitz	<b>Subscriber Preferred Rates:</b>	
<b>Approval Date:</b>	05/24/2017	<b>Product Variants:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	TUV SUD China Ltd (A)		
<b>Test Document:</b>			

### Description

This certificate and its information was migrated from a previous database

### History

#1 - 07/08/2021 04:47 PM - Herbert Falk

- File 17-D 17 05 92391 024-CYG SUNRI\_PRS-7367\_IEC61850Ed2-Server-Certificate added

### Files

17-D 17 05 92391 024-CYG SUNRI\_PRS-7367\_IEC61850Ed2-Server-Certificate.pdf 07/08/2021

Herbert Falk