

IEC 61850 Certificate - IEC 61850 Certificate #2628

Easergy MiCOM P345 Generator Protection [Schneider Electric Industries SAS]

07/08/2021 04:47 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	D 17 05 8919 1016
61850 Edition:	Edition 2	Certificate Hash:	AC74006DA7B3D5062D5D472E431F44 29F6308D60ECBB861A119D756BD768 7822
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Schneider Electric Industries SAS	Vendor Artifact Hash:	
Address:	35 rue Joseph Monier 92500 Rueil-Malmaison, France	Umbrella Organization:	Schneider Electric
Product:	Easergy MiCOM P345 Generator Protection	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	B2	Publisher Legacy Variants:	
Key Words:	Protection, Relay	Publisher Preferred Rates:	
Test Procedure Version:	1.0	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	06/09/2017	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	TUV SUD China Ltd (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:47 PM - Herbert Falk

- File 17-D 17 05 89191 016-Schneider Electric_MiCOM P345_IEC61850Ed2-Server- added

#2 - 07/09/2021 09:11 AM - Herbert Falk

- Umbrella Organization set to Schneider Electric

Files

17-D 17 05 89191 016-Schneider Electric_MiCOM P345_IEC61850Ed2-Server.pdf 07/08/2021

Herbert Falk