

IEC 61850 Certificate - IEC 61850 Certificate #2629

EPIC-M2500 Power Meter [NEOPIS Co., Ltd.]

07/08/2021 04:47 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	17-029674-04
61850 Edition:	Edition 2	Certificate Hash:	2DB29A0B8413C795EE1624B32A9FC9 B5AA617F5F4C8CD50613BF613A0F2E 0664
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	NEOPIS Co., Ltd.	Vendor Artifact Hash:	
Address:	14086 Neo Bd, 47, Jeonpa-ro 24beon-gil, Manan-gu, Anyang-si, Gyeonggi-do, Korea	Umbrella Organization:	
Product:	EPIC-M2500 Power Meter	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	1.0	Publisher Legacy Variants:	
Key Words:	Measurement, Meter	Publisher Preferred Rates:	
Test Procedure Version:	1.0	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	06/13/2017	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Korea Testing Laboratory (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:47 PM - Herbert Falk

- File 17-029674-04_Certificate_Neopis_Server_Ed2_TP_1p0_TPCL_1p2p1_KTL.pdf added

Files

17-029674-04_Certificate_Neopis_Server_Ed2_TP_1p0_TPCL_1p2p1_KTL.pdf

07/08/2021

Herbert Falk