

IEC 61850 Certificate - IEC 61850 Certificate #2630

HUSKY RTU 6049-E70 Remote Terminal Unit [Synergy Systems & Solutions]

07/08/2021 04:47 PM - Herbert Falk

Status:	Approved	Certificate Name:	10050571-INC 17-2301
Priority:	Normal	Certificate Hash:	5AFAAD24BE05EEDC65BF96F6F2A68 5D8FCC6AC46FD52627A33F3D12BAE C0E3DD
61850 Edition:	Edition 2	Vendor Artifact File Name:	
61850 Tested Aspects:	Client	Vendor Artifact Hash:	
Company:	Synergy Systems & Solutions	Umbrella Organization:	
Address:	A 1526, Green Fields Colony Faridadad, Haryana 121001 India	Optional Reservation Test:	Yes
Product:	HUSKY RTU 6049-E70 Remote Terminal Unit	Serial Number:	
HW Version:		Publisher Legacy Variants:	
SW Version:	5.1	Publisher Preferred Rates:	
Key Words:	Comm	Publisher Preferred Variants:	
Test Procedure Version:	1.0	Subscriber Legacy Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), SBO Control (12b), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Preferred Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Rates:	
Approval Date:	06/19/2017	Product Variants:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Test Document:			
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:47 PM - Herbert Falk

- File 17-2301_DNVGL_SynergySystemsSolutions_HUSKY_RTU_6049-E70_ClientEd2_Cer added

#2 - 07/11/2021 10:10 AM - Herbert Falk

- Address updated

- Optional Reservation Test changed from No to Yes

Files

