

IEC 61850 Certificate - IEC 61850 Certificate #2631

DRAGON RFI-D Overcurrent Protection [RoCon PLC]

07/08/2021 04:48 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	10035125-INC 17-2222
61850 Edition:	Edition 2	Certificate Hash:	F6CC07D2D424D8DF39170BFB5A879F 9DBF72FD8E652380E1145B8F912219 B505
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	RoCon PLC	Vendor Artifact Hash:	
Address:	56A, 21-th Century Str. 1700 Sofia Bulgaria	Umbrella Organization:	
Product:	DRAGON RFI-D Overcurrent Protection	Optional Reservation Test:	No
HW Version:	4	Serial Number:	
SW Version:	4.050/24.05.17	Publisher Legacy Variants:	
Key Words:	Protection, Relay	Publisher Preferred Rates:	
Test Procedure Version:	1.0	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Service Tracking (B15), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	06/29/2017	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:48 PM - Herbert Falk

- File 17-2222_Rev1_DNVGL_ROCON_RFI-D_ServerEd2_Certificate.pdf added

Files

17-2222_Rev1_DNVGL_ROCON_RFI-D_ServerEd2_Certificate.pdf 92.4 KB

07/08/2021

Herbert Falk