

# IEC 61850 Certificate - IEC 61850 Certificate #2638

## ABB SACE Emax2 Ekip COM IEC61850 [ABB SACE Division]

07/08/2021 04:48 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	1 KHL050114
<b>61850 Edition:</b>	Edition 1	<b>Certificate Hash:</b>	9A4E584461945F4B1AFDDDD76FF5C2C 018CB945E0A4C456E1C810545921D2 7ED3
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	ABB SACE Division	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	Via Baioni 35 24123 Bergamo ITALY	<b>Umbrella Organization:</b>	
<b>Product:</b>	ABB SACE Emax2 Ekip COM IEC61850	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>		<b>Serial Number:</b>	
<b>SW Version:</b>	3.01	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>	Breaker	<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	3.03	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Data Sets (B2), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	bruce.muschlitz	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	07/20/2017	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	ABB Switzerland Ltd. (B)		
<b>Description</b>			
This certificate and its information was migrated from a previous database			

### History

#1 - 07/08/2021 04:48 PM - Herbert Falk

- File 1KHL050114\_IEC61850ConformanceCertificate\_ServerEd1\_Emax2\_Ekip\_Com\_v.3 added

### Files

1KHL050114\_IEC61850ConformanceCertificate\_ServerEd1\_Emax2\_Ekip\_Com\_v.3.pdf 07/08/2021

Herbert Falk