

IEC 61850 Certificate - IEC 61850 Certificate #2639

PCS-9710 REMOTE TERMINAL UNIT [NR Electric Co., Ltd.]

07/08/2021 04:48 PM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 2	Certificate Name: D 17 07 61589 102
61850 Tested Aspects:	Client	Certificate Hash: C08EF7AF30C343852B3EDECC3A536083F5D5A74DDECDEF60C18EB473032656BC
Company:	NR Electric Co., Ltd.	Vendor Artifact File Name:
Address:	69 Suyuan Avenue, Jiangning 211106, Nanjing, People's Republic of China	Vendor Artifact Hash:
Product:	PCS-9710 REMOTE TERMINAL UNIT	Umbrella Organization:
HW Version:		Optional Reservation Test: No
SW Version:	3.05	Serial Number:
Key Words:	RTU	Publisher Legacy Variants:
Test Procedure Version:	1.0	Publisher Preferred Rates:
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), SBO Control (12b), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Legacy Variants:
Approval Date:	07/21/2017	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates:
Current Test Lab Name:	TUV SUD China Ltd (A)	Product Variants:
Test Document:		Time Activated Control:
Description This certificate and its information was migrated from a previous database		

History

#1 - 07/08/2021 04:48 PM - Herbert Falk

- File 17-D 17 07 61589 102-NR Electric_PCS-9710_IEC61850Ed2-Client-Certifica added

Files

17-D 17 07 61589 102-NR Electric_PCS-9710_IEC61850Ed2-Client-Certifica.pdf	07/08/2021	Herbert Falk
--	------------	--------------