

IEC 61850 Certificate - IEC 61850 Certificate #2641

TOPAZ IEC DAS MX240 + TM BIN16 and PM7 [PLC Technology]

07/08/2021 04:48 PM - Herbert Falk

| | | | |
|-------------------------------------|---|---------------------------------------|--|
| Status: | Approved | Test Document: | |
| Priority: | Normal | Certificate Name: | 10057347-INC 17-2443 |
| 61850 Edition: | Edition 2 | Certificate Hash: | D63586EFC6A1E90DB3B702FFF0C89 CF6F3B35BB688A5EDDB471241C85C F4E239 |
| 61850 Tested Aspects: | Server | Vendor Artifact File Name: | |
| Company: | PLC Technology | Vendor Artifact Hash: | |
| Address: | 117449 Vinokurova st. 3 Moscow Russian Federation | Umbrella Organization: | |
| Product: | TOPAZ IEC DAS MX240 + TM BIN16 and PM7 | Optional Reservation Test: | No |
| HW Version: | | Serial Number: | |
| SW Version: | v.2.1.0.4 with core v.2.0.2.1 | Publisher Legacy Variants: | |
| Key Words: | Comm, Measurement | Publisher Preferred Rates: | |
| Test Procedure Version: | 1.0 | Publisher Preferred Variants: | |
| IEC 61850 Blocks Certified: | Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Time Synchronization (B13), Unbuffered Reporting (B5) | Subscriber Legacy Variants: | |
| Certificate/Result Reviewer: | bruce.muschlitz | Subscriber Preferred Variants: | |
| Approval Date: | 08/09/2017 | Subscriber Preferred Rates: | |
| Standards Tested: | 61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1 | | |
| Current Test Lab Name: | DNV Netherlands (A) | | |

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:48 PM - Herbert Falk

- File 17-2443_DNVGL_PLG-Technology_TOPAZ_IEC_DAS_ServerEd2_Certificate.pdf added

Files

17-2443_DNVGL_PLG-Technology_TOPAZ_IEC_DAS_ServerEd2_Certificate.pdf 07/08/2021

Herbert Falk