

IEC 61850 Certificate - IEC 61850 Certificate #2642

SEL-451 Protection, Automation, Bay Ctrl [Schweitzer Engineering Laboratories, Inc.]

07/08/2021 04:48 PM - Herbert Falk

<p>Status: Approved</p> <p>Priority: Normal</p> <p>61850 Edition: Edition 2</p> <p>61850 Tested Aspects: Server</p> <p>Company: Schweitzer Engineering Laboratories, Inc.</p> <p>Address: 2350 NE Hopkins Court Pullman, WA 99163 USA</p> <p>Product: SEL-451 Protection, Automation, Bay Ctrl</p> <p>HW Version:</p> <p>SW Version: R320 + 61850 library 55CCEC31</p> <p>Key Words: Bay Controller, Protection, Relay</p> <p>Test Procedure Version: 1.0</p> <p>IEC 61850 Blocks Certified: Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)</p> <p>Certificate/Result Reviewer: bruce.muschlitz</p> <p>Approval Date: 08/09/2017</p> <p>Standards Tested: 61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1</p> <p>Current Test Lab Name: DNV Netherlands (A)</p>	<p>Test Document:</p> <p>Certificate Name: 10051563-INC 17-2452</p> <p>Certificate Hash: 078A60FEF1165DAE67D9A8C45B8536 F845B6254D2A66042E7AA542DD3910 D5B5</p> <p>Vendor Artifact File Name:</p> <p>Vendor Artifact Hash:</p> <p>Umbrella Organization:</p> <p>Optional Reservation Test: No</p> <p>Serial Number:</p> <p>Publisher Legacy Variants:</p> <p>Publisher Preferred Rates:</p> <p>Publisher Preferred Variants:</p> <p>Subscriber Legacy Variants:</p> <p>Subscriber Preferred Variants:</p> <p>Subscriber Preferred Rates:</p>
<p>Description</p> <p>This certificate and its information was migrated from a previous database</p>	

History

#1 - 07/08/2021 04:48 PM - Herbert Falk

- File 17-2452_DNVGL_SEL_SEL-451_ServerEd2_Certificate.pdf added

Files

17-2452_DNVGL_SEL_SEL-451_ServerEd2_Certificate.pdf	87.9 KB	07/08/2021	Herbert Falk
---	---------	------------	--------------