

IEC 61850 Certificate - IEC 61850 Certificate #2643

Easergy MiCOM P643 Transformer prot rela [Schneider Electric Industries SAS]

07/08/2021 04:48 PM - Herbert Falk

| | | | |
|--|---|---------------------------------------|--|
| Status: | Approved | Test Document: | |
| Priority: | Normal | Certificate Name: | 10051683-INC 17-2213 |
| 61850 Edition: | Edition 2 | Certificate Hash: | A9D726A4711E57DDDFDAC963AE7D8 FABE72E8E1996125606491B0D6C39A 61521 |
| 61850 Tested Aspects: | Server | Vendor Artifact File Name: | |
| Company: | Schneider Electric Industries SAS | Vendor Artifact Hash: | |
| Address: | 35 rue Joseph Monier 92500 Rueil-Malmaison, France | Umbrella Organization: | Schneider Electric |
| Product: | Easergy MiCOM P643 Transformer prot rela | Optional Reservation Test: | No |
| HW Version: | M | Serial Number: | |
| SW Version: | B2 | Publisher Legacy Variants: | |
| Key Words: | Differential, Protection, Relay | Publisher Preferred Rates: | |
| Test Procedure Version: | 1/0 | Publisher Preferred Variants: | |
| IEC 61850 Blocks Certified: | Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5) | Subscriber Legacy Variants: | |
| Certificate/Result Reviewer: | bruce.muschlitz | Subscriber Preferred Variants: | |
| Approval Date: | 08/10/2017 | Subscriber Preferred Rates: | |
| Standards Tested: | 61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1 | | |
| Current Test Lab Name: | DNV Netherlands (A) | | |
| Description | | | |
| This certificate and its information was migrated from a previous database | | | |

History

#1 - 07/08/2021 04:48 PM - Herbert Falk

- File 17-2213-DNVGL_Schneider Electric_P643_ServerEd2_Certificate.pdf added

#2 - 07/09/2021 09:11 AM - Herbert Falk

- Umbrella Organization set to Schneider Electric

Files

17-2213-DNVGL_Schneider Electric_P643_ServerEd2_Certificate.pdf 91.2 KB

07/08/2021

Herbert Falk