

IEC 61850 Certificate - IEC 61850 Certificate #2646

SIPROTEC 5 7UM85 Generator protection [Siemens AG, EM DG PRO]

07/08/2021 04:48 PM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 2	Certificate Name: 10033462-INC 17-2187
61850 Tested Aspects:	Server	Certificate Hash: 9FDC2E887C2F104AEB28F03FEFC1C D8B9AD97DBC2E43453639DDF3200 1D9EC0
Company:	Siemens AG, EM DG PRO	Vendor Artifact File Name:
Address:	Wernerwerkdamm 5 13629 Berlin Germany	Vendor Artifact Hash:
Product:	SIPROTEC 5 7UM85 Generator protection	Umbrella Organization:
HW Version:	7UM85-DAAA-AA0-0AAA0-AZ3111-1311	Optional Reservation Test: No
SW Version:	V07.50	Serial Number:
Key Words:	Differential, Protection	Publisher Legacy Variants:
Test Procedure Version:	1.0	Publisher Preferred Rates:
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Service Tracking (B15), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Legacy Variants:
Approval Date:	09/15/2017	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates:
Current Test Lab Name:	DNV Netherlands (A)	Product Variants:
Test Document:		Time Activated Control:
Description This certificate and its information was migrated from a previous database		

History

#1 - 07/08/2021 04:48 PM - Herbert Falk

- File 17-2187_DNVGL_SIEMENS_7UM85_ServerEd2_Certificate.pdf added

Files

17-2187_DNVGL_SIEMENS_7UM85_ServerEd2_Certificate.pdf	94.4 KB	07/08/2021	Herbert Falk
---	---------	------------	--------------