

## IEC 61850 Certificate - IEC 61850 Certificate #2647

### IEDScout 4.20 - Versatile software tool [OMICRON Electronics GmbH]

07/08/2021 04:48 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Certificate Name:</b>	D 17 08 17955 101
<b>Priority:</b>	Normal	<b>Certificate Hash:</b>	C8F992A580583CFAFFD5D260C40271 45209BA41829E1DEE824C8BC73366D 71AD
<b>61850 Edition:</b>	Edition 2	<b>Vendor Artifact File Name:</b>	
<b>61850 Tested Aspects:</b>	Client	<b>Vendor Artifact Hash:</b>	
<b>Company:</b>	OMICRON Electronics GmbH	<b>Umbrella Organization:</b>	
<b>Address:</b>	Oberes Ried 1 A-6833 Klaus Austria	<b>Optional Reservation Test:</b>	Yes
<b>Product:</b>	IEDScout 4.20 - Versatile software tool	<b>Serial Number:</b>	
<b>HW Version:</b>	Lenovo T540P + Windows7 Ent. SP1	<b>Publisher Legacy Variants:</b>	
<b>SW Version:</b>	4.20	<b>Publisher Preferred Rates:</b>	
<b>Key Words:</b>	Comm, Test Tool	<b>Publisher Preferred Variants:</b>	
<b>Test Procedure Version:</b>	1.0	<b>Subscriber Legacy Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), SBO Control (12b), Service Tracking (B15), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Preferred Variants:</b>	
<b>Certificate/Result Reviewer:</b>	bruce.muschlitz	<b>Subscriber Preferred Rates:</b>	
<b>Approval Date:</b>	09/19/2017	<b>Product Variants:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	TUV SUD China Ltd (A)		
<b>Test Document:</b>			

#### Description

This certificate and its information was migrated from a previous database

#### History

##### #1 - 07/08/2021 04:48 PM - Herbert Falk

- File 17-D 17 08 17955 101-OMICRON\_IEDScout4.20\_IEC61850Ed2-Client-Certifica added

##### #2 - 07/11/2021 10:10 AM - Herbert Falk

- Address updated

- Optional Reservation Test changed from No to Yes

**Files**

17-D 17 08 17955 101-OMICRON\_IEDScout4.20\_IEC61850Ed2-Client-Case.pdf 07/08/2021

Herbert Falk