

IEC 61850 Certificate - IEC 61850 Certificate #2648

Survalent SCADA [Survalent Technology Corporation]

07/08/2021 04:48 PM - Herbert Falk

Status:	Approved	Certificate Name:	10057361 INC 17-2566
Priority:	Normal	Certificate Hash:	9E13836B2BC7833585A265504489071 3295C7BE6702EC5E6E1608D5E689B3 154
61850 Edition:	Edition 2	Vendor Artifact File Name:	
61850 Tested Aspects:	Client	Vendor Artifact Hash:	
Company:	Survalent Technology Corporation	Umbrella Organization:	
Address:	Survalent Technology Corporation 7965 Heritage Road Brampton, Ontario L6Y 5X5 Canada	Optional Reservation Test:	Yes
Product:	Survalent SCADA	Serial Number:	
HW Version:	Lenovo ThinkServer RD350	Publisher Legacy Variants:	
SW Version:	17.3 1.17.0828.1	Publisher Preferred Rates:	
Key Words:		Publisher Preferred Variants:	
Test Procedure Version:	1.0	Subscriber Legacy Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), SBO Control (12b), Unbuffered Reporting (B5)	Subscriber Preferred Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Rates:	
Approval Date:	10/04/2017	Product Variants:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Test Document:			
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:48 PM - Herbert Falk

- File 17-2566_DNV_GL_Survalent_Survalent_SCADA_ClientEd2_certificate.pdf added

#2 - 07/11/2021 10:10 AM - Herbert Falk

- Address updated

- Optional Reservation Test changed from No to Yes

Files

