

IEC 61850 Certificate - IEC 61850 Certificate #2650

SEL-3530 Real-Time Automation Controller [Schweitzer Engineering Laboratories, Inc.]

07/08/2021 04:48 PM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 2	Certificate Name: 10033472-INC 17-2601
61850 Tested Aspects:	Client	Certificate Hash: 4FA3727AF578509DACEB81451A5DFB E0E5A56D5E85E7839FAE2635E6712D 391B
Company:	Schweitzer Engineering Laboratories, Inc.	Vendor Artifact File Name:
Address:	2350 NE Hopkins Court Pullman WA 99163 USA	Vendor Artifact Hash:
Product:	SEL-3530 Real-Time Automation Controller	Umbrella Organization:
HW Version:		Optional Reservation Test: No
SW Version:	SEL-3530-R139-V1-Z001001-D201706	Serial Number:
Key Words:	Comm, Gateway	Publisher Legacy Variants:
Test Procedure Version:	1.0	Publisher Preferred Rates:
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), SBO Control (12b), Time Synchronization (B13), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Legacy Variants:
Approval Date:	10/11/2017	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates:
Current Test Lab Name:	DNV Netherlands (A)	Product Variants:
Test Document:		Time Activated Control:
Description This certificate and its information was migrated from a previous database		

History

#1 - 07/08/2021 04:48 PM - Herbert Falk

- File 17-2601_DNVGL_SEL_RTAC_3530 ClientEd2_Certificate.pdf added

Files

17-2601_DNVGL_SEL_RTAC_3530 ClientEd2_Certificate.pdf	90.3 KB	07/08/2021	Herbert Falk
---	---------	------------	--------------