

IEC 61850 Certificate - IEC 61850 Certificate #2652

IRL-F Dir Overcurrent Prot with Sens gro [ZIV GRID Automation S.L.]

07/08/2021 04:48 PM - Herbert Falk

Status:	Approved	Certificate Name:	84000187-INC 17-2731
Priority:	Normal	Certificate Hash:	92CBBC4521B7DD9A6A69BF287E5E4 DEB8E685245029E1F0CE57B861AA82 40B0A
61850 Edition:	Edition 1	Vendor Artifact File Name:	
61850 Tested Aspects:	Server	Vendor Artifact Hash:	
Company:	ZIV GRID Automation S.L.	Umbrella Organization:	
Address:	Parque Tecnológico, Edificio 210-48170 Zamudio, Bizkaia Spain	Optional Reservation Test:	No
Product:	IRL-F Dir Overcurrent Prot with Sens gro	Serial Number:	
HW Version:	IRL-F-1BCAAABAA0A	Publisher Legacy Variants:	
SW Version:	0.7.1	Publisher Preferred Rates:	
Key Words:	Protection, Relay	Publisher Preferred Variants:	
Test Procedure Version:	3.04	Subscriber Legacy Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Preferred Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Rates:	
Approval Date:	10/29/2017	Product Variants:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Test Document:			
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:48 PM - Herbert Falk

- File 17-2731_DNVGL_ZIV_IRL_ServerEd1_Certificate.pdf added

Files

17-2731_DNVGL_ZIV_IRL_ServerEd1_Certificate.pdf	88.6 KB	07/08/2021	Herbert Falk
---	---------	------------	--------------