IEC 61850 Certificate - IEC 61850 Certificate #2654

BME NOP 0300 Modicon M580 IEC61850 [Schneider Electric]

07/08/2021 04:48 PM - Herbert Falk

Status:	Approved		
Priority:	Normal		
61850 Edition:	Edition 2	**Certificate Name:**	D 17 10 02543 001
61850 Tested Aspects:	Client	**Certificate Hash:**	0921D7E2CC09B82D568C2A2CBA1C4B9945013A271A41AF6960712BC19B75601B
Company:	Schneider Electric	**Vendor Artifact File Name:**	
Address:	8eme rue, 70 Metres ZI Carros, 06510, Carros CEDEX, FRANCE	**Vendor Artifact Hash:**	
Product:	BME NOP 0300 Modicon M580 IEC61850	**Umbrella Organization:**	Schneider Electric
HW Version:		**Optional Reservation Test:**	Yes
SW Version:	2.0	**Serial Number:**	
Key Words:	Comm, Gateway	**Publisher Legacy Variants:**	
Test Procedure Version:	1.0	**Publisher Preferred Rates:**	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), SBO Control (12b), Unbuffered Reporting (B5)	**Publisher Preferred Variants:**	
Certificate/Result Reviewer:	bruce.muschlitz	**Subscriber Legacy Variants:**	
Approval Date:	11/01/2017	**Subscriber Preferred Variants:**	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-8-1	**Subscriber Preferred Rates:**	
Current Test Lab Name:	TUV SUD China Ltd (A)	**Product Variants:**	
Test Document:			

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:48 PM - Herbert Falk

- File 17-D 17 10 02543 001-Schneider Electric_BMENOP0300_IEC61850Ed2-Client- added

#2 - 07/09/2021 09:11 AM - Herbert Falk

- Umbrella Organization set to Schneider Electric

#3 - 07/11/2021 10:11 AM - Herbert Falk

- Address updated

- Optional Reservation Test changed from No to Yes

Files