

# IEC 61850 Certificate - IEC 61850 Certificate #2654

## BME NOP 0300 Modicon M580 IEC61850 [Schneider Electric]

07/08/2021 04:48 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	D 17 10 02543 001
<b>61850 Edition:</b>	Edition 2	<b>Certificate Hash:</b>	0921D7E2CC09B82D568C2A2CBA1C4 B9945013A271A41AF6960712BC19B75 601B
<b>61850 Tested Aspects:</b>	Client	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	Schneider Electric	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	8eme rue, 70 Metres ZI Carros, 06510, Carros CEDEX, FRANCE	<b>Umbrella Organization:</b>	Schneider Electric
<b>Product:</b>	BME NOP 0300 Modicon M580 IEC61850	<b>Optional Reservation Test:</b>	Yes
<b>HW Version:</b>		<b>Serial Number:</b>	
<b>SW Version:</b>	2.0	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>	Comm, Gateway	<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	1.0	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), SBO Control (12b), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	bruce.muschlitz	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	11/01/2017	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-8-1		
<b>Current Test Lab Name:</b>	TUV SUD China Ltd (A)		
<b>Description</b>			
This certificate and its information was migrated from a previous database			

### History

#### #1 - 07/08/2021 04:48 PM - Herbert Falk

- File 17-D 17 10 02543 001-Schneider Electric\_BMENOP0300\_IEC61850Ed2-Client- added

#### #2 - 07/09/2021 09:11 AM - Herbert Falk

- Umbrella Organization set to Schneider Electric

#### #3 - 07/11/2021 10:11 AM - Herbert Falk

- Address updated

- Optional Reservation Test changed from No to Yes

### Files

17-D 17 10 02543 001-Schneider Electric\_BMENOP0300\_IEC61850Ed2-Client.pdf 07/08/2021

Herbert Falk