

IEC 61850 Certificate - IEC 61850 Certificate #2655

ETR600-SL Protection & Control Device [ENTEC Electric & Electronic Co., Ltd.]

07/08/2021 04:48 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	2017TS02772
61850 Edition:	Edition 2	Certificate Hash:	64E42754C5FC04E08B3C6042C57DC5 077C55FACA7F01B6CFE319EE4A3472 3326
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	ENTEC Electric & Electronic Co., Ltd.	Vendor Artifact Hash:	
Address:	225-38 Choirubaekro, Bongdam-eup, Hwasung-city Gyeonggido, 445-894 Republic of Korea	Umbrella Organization:	
Product:	ETR600-SL Protection & Control Device	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	1.0.0.0/1.1.0.0/1.1.1.0	Publisher Legacy Variants:	
Key Words:	Protection, Relay	Publisher Preferred Rates:	
Test Procedure Version:	1.0	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	11/01/2017	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Korea Electrotechnology Research Institute (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:48 PM - Herbert Falk

- File 2017TS02772_ENTEC_ETR600-SL_Server2.0_KERI.pdf added

Files

2017TS02772_ENTEC_ETR600-SL_Server2.0_KERI.pdf	2.25 MB	07/08/2021	Herbert Falk
--	---------	------------	--------------