

IEC 61850 Certificate - IEC 61850 Certificate #2662

PS6000+ Substation Automation System Sca [Guo Dian Nanjing Automation Co., Ltd.]

07/08/2021 04:49 PM - Herbert Falk

Status:	Approved	Certificate Name:	D 17 11 02427 002
Priority:	Normal	Certificate Hash:	26CCEF8D8DBE212E31AD2D8171C21 E48751664FA734081B70F4337574E48 4302
61850 Edition:	Edition 2	Vendor Artifact File Name:	
61850 Tested Aspects:	Client	Vendor Artifact Hash:	
Company:	Guo Dian Nanjing Automation Co., Ltd.	Umbrella Organization:	
Address:	No.39, Shuige Road, Jiangning Development Zone, 211153, Nanjing, People's Republic of China	Optional Reservation Test:	Yes
Product:	PS6000+ Substation Automation System Sca	Serial Number:	
HW Version:		Publisher Legacy Variants:	
SW Version:	2.0	Publisher Preferred Rates:	
Key Words:	Gateway, RTU	Publisher Preferred Variants:	
Test Procedure Version:	1.0	Subscriber Legacy Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), SBO Control (12b), Service Tracking (B15), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Preferred Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Rates:	
Approval Date:	11/17/2017	Product Variants:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	TUV SUD China Ltd (A)		
Test Document:			

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:49 PM - Herbert Falk

- File 17-D 17 11 02427 002-SAC_PS6000P_IEC61850Ed2-Client-Certificate.pdf added

#2 - 07/11/2021 10:11 AM - Herbert Falk

- Address updated

- Optional Reservation Test changed from No to Yes

Files

17-D 17 11 02427 002-SAC_PS6000P_IEC61850Ed2-Client-Certificate.pdf

07/08/2021

Herbert Falk