

IEC 61850 Certificate - IEC 61850 Certificate #2663

SEL-401 Prot, Autom, Contrl Merging Unit [Schweitzer Engineering Laboratories, Inc.]

07/08/2021 04:49 PM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 2	Certificate Name: 10030052-INC 17-2746
61850 Tested Aspects:	Server	Certificate Hash: 1CEDD13367D2BF51F168BABD2B23F A687A06C5D7C64CEDD8E3140493A91 A17E8
Company:	Schweitzer Engineering Laboratories, Inc.	Vendor Artifact File Name:
Address:	2350 NE Hopkins Court Pullman, WA 99163 USA	Vendor Artifact Hash:
Product:	SEL-401 Prot, Autom, Contrl Merging Unit	Umbrella Organization:
HW Version:		Optional Reservation Test: No
SW Version:	V0-Z100001-D20170918	Serial Number:
Key Words:	Measurement, Merging Unit, Protection, Relay	Publisher Legacy Variants:
Test Procedure Version:	1.0	Publisher Preferred Rates:
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Legacy Variants:
Approval Date:	11/17/2017	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates:
Current Test Lab Name:	DNV Netherlands (A)	Product Variants:
Test Document:		Time Activated Control:
Description This certificate and its information was migrated from a previous database		

History

#1 - 07/08/2021 04:49 PM - Herbert Falk

- File 17-2746_DNVGL_SEL_SEL-401_ServerEd2_Certificate.pdf added

Files

17-2746_DNVGL_SEL_SEL-401_ServerEd2_Certificate.pdf	88.3 KB	07/08/2021	Herbert Falk
---	---------	------------	--------------