

IEC 61850 Certificate - IEC 61850 Certificate #2664

SEL-3505 Real-Time Automation Controller [Schweitzer Engineering Laboratories, Inc.]

07/08/2021 04:49 PM - Herbert Falk

Status:	Approved	Certificate Name:	10033472-INC 17-2676
Priority:	Normal	Certificate Hash:	F21E1BAEFFAAD65F60D701C1A320C 9C438C9ABBFED3904647CC1325BB21 34997
61850 Edition:	Edition 2	Vendor Artifact File Name:	
61850 Tested Aspects:	Server	Vendor Artifact Hash:	
Company:	Schweitzer Engineering Laboratories, Inc.	Umbrella Organization:	
Address:	2350 NE Hopkins Court Pullman, WA 99163 USA	Optional Reservation Test:	No
Product:	SEL-3505 Real-Time Automation Controller	Serial Number:	
HW Version:		Publisher Legacy Variants:	
SW Version:	3505-3-R139-V1-Z001001-D20170628	Publisher Preferred Rates:	
Key Words:	RTU	Publisher Preferred Variants:	
Test Procedure Version:	1.0	Subscriber Legacy Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Preferred Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Rates:	
Approval Date:	11/19/2017	Product Variants:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Test Document:			

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:49 PM - Herbert Falk

- File 17-2676_DNVGL_SEL-3505 RTAC_ServerEd2_Certificate.pdf added

Files

17-2676_DNVGL_SEL-3505 RTAC_ServerEd2_Certificate.pdf	93.7 KB	07/08/2021	Herbert Falk
---	---------	------------	--------------