

IEC 61850 Certificate - IEC 61850 Certificate #2668

SEL-3530 Real-Time Automation Controller [Schweitzer Engineering Laboratories, Inc.]

07/08/2021 04:49 PM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 2	Certificate Name: 10033472-INC 17-2673
61850 Tested Aspects:	Server	Certificate Hash: 2BB06F4AEA034B95C6D421DBA1DC4CF951587B232FC140D2B66B96C5EE8DA035
Company:	Schweitzer Engineering Laboratories, Inc.	Vendor Artifact File Name:
Address:	2350 NE Hopkins Court Pullman, WA 99163 USA	Vendor Artifact Hash:
Product:	SEL-3530 Real-Time Automation Controller	Umbrella Organization:
HW Version:		Optional Reservation Test: No
SW Version:	3530-R139-V1-Z001001-D20170628	Serial Number:
Key Words:	RTU	Publisher Legacy Variants:
Test Procedure Version:	1.0	Publisher Preferred Rates:
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Time Synchronization (B13), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Legacy Variants:
Approval Date:	11/19/2017	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates:
Current Test Lab Name:	DNV Netherlands (A)	Product Variants:
Test Document:		Time Activated Control:
Description This certificate and its information was migrated from a previous database		

History

#1 - 07/08/2021 04:49 PM - Herbert Falk

- File 17-2673_DNVGL_SEL-3530_ServerEd2_Certificate.pdf added

Files

17-2673_DNVGL_SEL-3530_ServerEd2_Certificate.pdf	93.6 KB	07/08/2021	Herbert Falk
--	---------	------------	--------------