

IEC 61850 Certificate - IEC 61850 Certificate #2671

SEL-451 Protection, Automation, and Bay [Schweitzer Engineering Laboratories, Inc.]

07/08/2021 04:49 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	10069983-INC 17-2851
61850 Edition:	Edition 2	Certificate Hash:	6E5675D396A2CF47B0657636B271930 EB371D27B8634B386B356025D866E9 BA8
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Schweitzer Engineering Laboratories, Inc.	Vendor Artifact Hash:	
Address:	2350 NE Hopkins Court Pullman, WA 99163 USA	Umbrella Organization:	
Product:	SEL-451 Protection, Automation, and Bay	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	451-5-R321-V0-Z024012-D20171008	Publisher Legacy Variants:	
Key Words:	Bay Controller, Protection, Relay	Publisher Preferred Rates:	
Test Procedure Version:	1.0	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	11/23/2017	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:49 PM - Herbert Falk

- File 17-2851_DNVGL_SEL_SEL-451_SEL-421_SEL-487B_SEL-487E_ServerEd2_Certific added

Files

17-2851_DNVGL_SEL_SEL-451_SEL-421_SEL-487B_SEL-487E_ServerEd2_Certificat 07/08/2021

Herbert Falk