

IEC 61850 Certificate - IEC 61850 Certificate #2673

SEL-421-7S Protection, Automation, and C [Schweitzer Engineering Laboratories, Inc.]

07/08/2021 04:49 PM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 2	Certificate Name: 10030052-INC 17-2750
61850 Tested Aspects:	Server	Certificate Hash: 21B1E28186C1F732E256A9F2D5D48C CDBFDF05B65D8A79E8B8DA676CA52 D976A
Company:	Schweitzer Engineering Laboratories, Inc.	Vendor Artifact File Name:
Address:	2350 NE Hopkins Court Pullman, WA 99163 USA	Vendor Artifact Hash:
Product:	SEL-421-7S Protection, Automation, and C	Umbrella Organization:
HW Version:		Optional Reservation Test: No
SW Version:	421-7-R402-V0-Z100001-D20171006	Serial Number:
Key Words:	Protection, Relay	Publisher Legacy Variants:
Test Procedure Version:	1.0	Publisher Preferred Rates:
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Legacy Variants:
Approval Date:	11/23/2017	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-8-1	Subscriber Preferred Rates:
Current Test Lab Name:	DNV Netherlands (A)	Product Variants:
Test Document:		Time Activated Control:
Description This certificate and its information was migrated from a previous database		

History

#1 - 07/08/2021 04:49 PM - Herbert Falk

- File 17-2750_DNVGL_SEL_SEL-421-7S_ServerEd2_Certificate.pdf added

Files

17-2750_DNVGL_SEL_SEL-421-7S_ServerEd2_Certificate.pdf	88.4 KB	07/08/2021	Herbert Falk
--	---------	------------	--------------