

IEC 61850 Certificate - IEC 61850 Certificate #2674

SEL-421-7P Protection, Automation, and C [Schweitzer Engineering Laboratories, Inc.]

07/08/2021 04:49 PM - Herbert Falk

Status:	Approved	Certificate Name:	10030052-INC 17-2748
Priority:	Normal	Certificate Hash:	6EE8C6D665A37CB4B858CF15C415D A55AB5F260235BB71D27961536E6498 1922
61850 Edition:	Edition 2	Vendor Artifact File Name:	
61850 Tested Aspects:	Server	Vendor Artifact Hash:	
Company:	Schweitzer Engineering Laboratories, Inc.	Umbrella Organization:	
Address:	2350 NE Hopkins Court Pullman, WA 99163 USA	Optional Reservation Test:	No
Product:	SEL-421-7P Protection, Automation, and C	Serial Number:	
HW Version:		Publisher Legacy Variants:	
SW Version:	421-7-R402-V0-Z100001-D20171006	Publisher Preferred Rates:	
Key Words:	Protection, Relay	Publisher Preferred Variants:	
Test Procedure Version:	1.0	Subscriber Legacy Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Preferred Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Rates:	
Approval Date:	11/23/2017	Product Variants:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Test Document:			
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:49 PM - Herbert Falk

- File 17-2748_DNVGL_SEL_SEL-421-7P_ServerEd2_Certificate.pdf added

Files

17-2748_DNVGL_SEL_SEL-421-7P_ServerEd2_Certificate.pdf	88.3 KB	07/08/2021	Herbert Falk
--	---------	------------	--------------