

IEC 61850 Certificate - IEC 61850 Certificate #2675

IED Interface Unit Server [Dowoo Digitech]

07/08/2021 04:49 PM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 1	Certificate Name: 17-054016-01-2
61850 Tested Aspects:	Server	Certificate Hash: 7FF66A5FF62473EA5E75AA7A8F7983CF547EF1D5D9833BEF2FA10658F1E51E48
Company:	Dowoo Digitech	Vendor Artifact File Name:
Address:	A-708, Ssangyong IT Twin Tower, Dunchon-daero, Jungwon-gu, Seongnam-si, Gyeonggi-do, Republic of Korea, 13216	Vendor Artifact Hash:
Product:	IED Interface Unit Server	Umbrella Organization:
HW Version:	DW-EPC-1000 Windows Emb. Stand 7	Optional Reservation Test: No
SW Version:	1.0	Serial Number:
Key Words:	Comm, Gateway	Publisher Legacy Variants:
Test Procedure Version:	3.03	Publisher Preferred Rates:
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), SBO Control (12b), Time Synchronization (B13), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Legacy Variants:
Approval Date:	11/27/2017	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates:
Current Test Lab Name:	Korea Testing Laboratory (A)	Product Variants:
Test Document:		Time Activated Control:
Description This certificate and its information was migrated from a previous database		

History

#1 - 07/08/2021 04:49 PM - Herbert Falk

- File 17-054016-01-2_DoWoo_DW-EPC-1000_Server_Ed1_Certification_KTL.pdf added

Files

17-054016-01-2_DoWoo_DW-EPC-1000_Server_Ed1_Certification_KTL.pdf	10 KB	07/08/2021	Herbert Falk
---	-------	------------	--------------