

IEC 61850 Certificate - IEC 61850 Certificate #2678

SEL-2241 Real-Time Automation Controller [Schweitzer Engineering Laboratories, Inc.]

07/08/2021 04:49 PM - Herbert Falk

Status:	Approved	Certificate Name:	10033472-INC 17-2809
Priority:	Normal	Certificate Hash:	A94A9F3538E37624E8BA5C0CACF371 6AF1C748E951178925DBC9991E4376 BEF1
61850 Edition:	Edition 2	Vendor Artifact File Name:	
61850 Tested Aspects:	Server	Vendor Artifact Hash:	
Company:	Schweitzer Engineering Laboratories, Inc.	Umbrella Organization:	
Address:	2350 NE Hopkins Court Pullman, WA 99163 USA	Optional Reservation Test:	No
Product:	SEL-2241 Real-Time Automation Controller	Serial Number:	
HW Version:		Publisher Legacy Variants:	
SW Version:	2241-R139-V1-Z001001-D20170628	Publisher Preferred Rates:	
Key Words:	RTU	Publisher Preferred Variants:	
Test Procedure Version:	1.0	Subscriber Legacy Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Preferred Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Product Variants:	
Approval Date:	12/06/2017		
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Test Document:			
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:49 PM - Herbert Falk

- File 17-2809_DNVGL_SEL-2241_ServerEd2_Certificate.pdf added

#2 - 07/09/2021 08:01 AM - Herbert Falk

- Umbrella Organization set to Schneider Electric

#3 - 07/09/2021 09:09 AM - Herbert Falk

- Umbrella Organization deleted (Schneider Electric)

Files

17-2809_DNVGL_SEL-2241_ServerEd2_Certificate.pdf

93.7 KB

07/08/2021

Herbert Falk