

IEC 61850 Certificate - IEC 61850 Certificate #2680

NSR-321 Breaker failure protection [NARI Technology Co., Ltd.]

07/08/2021 04:49 PM - Herbert Falk

Status:	Approved	Certificate Name:	10058714-INC 17-2863
Priority:	Normal	Certificate Hash:	1464DD488AC7B8FD86828503425989 E603E5ED7AEBAB9A327F2BCFC88BE 85608
61850 Edition:	Edition 2	Vendor Artifact File Name:	
61850 Tested Aspects:	Server	Vendor Artifact Hash:	
Company:	NARI Technology Co., Ltd.	Umbrella Organization:	
Address:	No. 19 Chengxin Avenue, 211106 211106 Nanjing, Jiangsu People's Republic of China	Optional Reservation Test:	No
Product:	NSR-321 Breaker failure protection	Serial Number:	
HW Version:	1.10 CDFDE96B	Publisher Legacy Variants:	
SW Version:	2.11	Publisher Preferred Rates:	
Key Words:	Protection, Relay	Publisher Preferred Variants:	
Test Procedure Version:	1.0	Subscriber Legacy Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Service Tracking (B15), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Preferred Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Rates:	
Approval Date:	12/08/2017	Product Variants:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Test Document:			
Description This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:49 PM - Herbert Falk

- File 17-2863_DNVGL_NARI-TECH_NSR-321_ServerEd2_Certificate.pdf added

Files

17-2863_DNVGL_NARI-TECH_NSR-321_ServerEd2_Certificate.pdf 91.6 KB

07/08/2021

Herbert Falk