

IEC 61850 Certificate - IEC 61850 Certificate #2681

NSR-372CU Distributed busbar protection [NARI Technology Co., Ltd.]

07/08/2021 04:49 PM - Herbert Falk

Status:	Approved	Certificate Name:	10058714-INC 17-2866
Priority:	Normal	Certificate Hash:	3A540F10E7808BD7C2416B69CBC010 C605725D72881971B1EE94B69F02759 B1A
61850 Edition:	Edition 2	Vendor Artifact File Name:	
61850 Tested Aspects:	Server	Vendor Artifact Hash:	
Company:	NARI Technology Co., Ltd.	Umbrella Organization:	
Address:	No. 19 Chengxin Avenue, 211106 211106 Nanjing, Jiangsu People's Republic of China	Optional Reservation Test:	No
Product:	NSR-372CU Distributed busbar protection	Serial Number:	
HW Version:	R1.50	Publisher Legacy Variants:	
SW Version:	1.00	Publisher Preferred Rates:	
Key Words:	Protection, Relay	Publisher Preferred Variants:	
Test Procedure Version:	1.0	Subscriber Legacy Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Enhanced SBO Control (12d), Service Tracking (B15), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Preferred Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Rates:	
Approval Date:	12/08/2017	Product Variants:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Test Document:			
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:49 PM - Herbert Falk

- File 17-2866_DNVGL_NARI-TECH_NSR-372CU_ServerEd2_Certificate.pdf added

Files

17-2866_DNVGL_NARI-TECH_NSR-372CU_ServerEd2_Certificate.pdf 10.6 KB

07/08/2021

Herbert Falk