

IEC 61850 Certificate - IEC 61850 Certificate #2682

IRF-A Directional Overcurrent MF Relay [ZIV GRID Automation S.L.]

07/08/2021 04:49 PM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 1	Certificate Name: 84000198-INC 17-2922
61850 Tested Aspects:	Server	Certificate Hash: C71BC895BBE9A5A3BFC8E8A571F2C6A8456801FDC7703AA20390E1F9619759F2
Company:	ZIV GRID Automation S.L.	Vendor Artifact File Name:
Address:	Parque Tecnológico, Edificio 210-48170 Zamudio, Bizkaia Spain	Vendor Artifact Hash:
Product:	IRF-A Directional Overcurrent MF Relay	Umbrella Organization:
HW Version:	: IRF-A-2142A00000000AA10	Optional Reservation Test: No
SW Version:	0.8.0	Serial Number:
Key Words:	Protection, Relay	Publisher Legacy Variants:
Test Procedure Version:	1.04	Publisher Preferred Rates:
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Legacy Variants:
Approval Date:	12/08/2017	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates:
Current Test Lab Name:	DNV Netherlands (A)	Product Variants:
Test Document:		Time Activated Control:
Description This certificate and its information was migrated from a previous database		

History

#1 - 07/08/2021 04:49 PM - Herbert Falk

- File 17-2922_DNVGL_ZIV_IRF-A_ServerEd1_Certificate.pdf added

Files

17-2922_DNVGL_ZIV_IRF-A_ServerEd1_Certificate.pdf	92 KB	07/08/2021	Herbert Falk
---	-------	------------	--------------